



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 407820

Matrix: Drinking Water
Received: 03/10/21
Reported: 03/15/21

Attn:
Project: 2020 Lead In Drinking Water
Location: East Rochester Union Free
Number: 2202959

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
407820-001	0303-ER-001	Kitchen Tap 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/11/21	SA
407820-002	0303-ER-002	Kitchen Tap 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/11/21	SA
407820-003	0303-ER-003	Kitchen Tap 3					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/11/21	SA
407820-004	0303-ER-004	Kitchen Tap 4					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/11/21	SA
407820-005	0303-ER-005	Kitchen Tap 5					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/11/21	SA
407820-006	0303-ER-006	Kitchen Tap 6					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/11/21	SA
407820-007	0303-ER-007	Kitchen Ice Machine					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/11/21	SA
407820-008	0303-ER-008	Kitchen Break Rm Tap					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	17.3	5.00	µg/L	03/11/21	SA
407820-009	0303-ER-009	Kitchen Tap					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/11/21	SA
407820-010	0303-ER-010	Maintenance Tap 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	22.0	5.00	µg/L	03/11/21	SA
407820-011	0303-ER-011	Maintenance Tap 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	16.4	5.00	µg/L	03/11/21	SA

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 407820

Matrix: Drinking Water
Received: 03/10/21
Reported: 03/15/21

Attn:
Project: 2020 Lead In Drinking Water
Location: East Rochester Union Free
Number: 2202959

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
407820-012	0303-ER-012	565 Girls Tap 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	5.69	5.00	µg/L	03/11/21	SA
407820-013	0303-ER-013	566 Girls Tap 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	5.94	5.00	µg/L	03/11/21	SA
407820-014	0303-ER-014	563 Boys Tap 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	25.0	5.00	µg/L	03/11/21	SA
407820-015	0303-ER-015	564 Boys Tap 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/11/21	SA
407820-016	0303-ER-016	Mens 100D Tap					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	9.78	5.00	µg/L	03/11/21	SA
407820-017	0303-ER-017	100E Teachers Lounge Tap					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/11/21	SA
407820-018	0303-ER-018	100C Womens Tap					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/11/21	SA
407820-019	0303-ER-019	Dishwasher Room Sprayer					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/11/21	SA
407820-020	0303-ER-020	Hall By Cafeteria Chiller					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/11/21	SA
407820-021	0303-ER-021	Hall By Cafeteria Chiller					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/11/21	SA
407820-022	0303-ER-022	Hall by Cafeteria Bottle					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/11/21	SA

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #:	407820
-----------------	--------

Matrix Drinking Water
Received 03/10/21
Reported 03/15/21

Attn:
Project: 2020 Lead In Drinking Water
Location: East Rochester Union Free
Number: 2202959

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
407820-023	0303-ER-023	501M Fork Room Tap					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	8.03	5.00	µg/L	03/11/21	SA
407820-024	0303-ER-024	507B Nurse Tap					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	5.28	5.00	µg/L	03/11/21	SA
407820-025	0303-ER-025	507C Hearing Tap					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/11/21	SA
407820-026	0303-ER-026	511 Girls Tap 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	25.7	5.00	µg/L	03/11/21	SA
407820-027	0303-ER-027	512 Girls Tap 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	30.4	5.00	µg/L	03/11/21	SA
407820-028	0303-ER-028	513 Girls Tap 3					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	23.3	5.00	µg/L	03/11/21	SA
407820-029	0303-ER-029	514 Girls Tap 4					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	24.8	5.00	µg/L	03/11/21	SA
407820-030	0303-ER-030	515 Girls Tap 5					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	264	250	µg/L	03/11/21	SA
407820-031	0303-ER-031	509 Boys Tap 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	56.4	10.0	µg/L	03/12/21	DLJ
407820-032	0303-ER-032	510 Boys Tap 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	53.9	10.0	µg/L	03/12/21	DLJ
407820-033	0303-ER-033	511 Boys Tap 3					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	61.3	10.0	µg/L	03/12/21	DLJ

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Labella Associates (1126)
Address: 300 State Street
Rochester, NY 14614-1098

Order #: 407820

Matrix Drinking Water
Received 03/10/21
Reported 03/15/21

Attn:
Project: 2020 Lead In Drinking Water
Location: East Rochester Union Free
Number: 2202959

PO Number:

Sample ID	Cust. Sample ID	Location	Result	RL*	Units	Analysis Date	Analyst
Parameter		Method					
407820-034	0303-ER-034	512 Boys Tap 4					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	79.0	25.0	µg/L	03/12/21	DLJ
407820-035	0303-ER-035	513 Boys Tap 5					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	52.9	10.0	µg/L	03/12/21	DLJ
407820-036	0303-ER-036	Hall By 511 Chiller 1					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/12/21	DLJ
407820-037	0303-ER-037	Hall By 511 Chiller 2					
Metals Analysis							
Lead		EPA 200.9 Rev 2.2	<5.00	5.00	µg/L	03/12/21	DLJ

407820-03/15/21 09:04 AM

Reviewed By: **Jennifer Lee**
Manager

EPA Regulatory Limits

Parameter	Reg. Limit	Unit
Lead	15.0	µg/L

State Certifications

Method	Parameter	New York	Virginia
EPA 200.9 Rev 2.2	Lead	ELAP Certified	VELAP Certified
State	Certificate Number		
New York	ELAP 61370		
Virginia	VELAP 11110		

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



300 Pearl Street, Suite 130 | Buffalo, NY 14202 | p 716-551-6281 | f 716-551-6282
www.labellapc.com

School East Rochester K-12 School
Date 3/3/2021

Sample #	Location	Outlet Type	Time	Notes
0303-ER-001	Kitchen	Tap 1	8:00 AM	
0303-ER-002	Kitchen	Tap 2	8:01 AM	
0303-ER-003	Kitchen	Tap 3	8:01 AM	
0303-ER-004	Kitchen	Tap 4	8:02 AM	
0303-ER-005	Kitchen	Tap 5	8:03 AM	
0303-ER-006	Kitchen	Tap 6	8:04 AM	
0303-ER-007	Kitchen	Ice Machine	8:07 AM	
0303-ER-008	Kitchen Break Rm	Tap	8:59 AM	
0303-ER-009	Kitchen	Tap	9:03 AM	
0303-ER-010	Maintenance	Tap 1	9:15 AM	
0303-ER-011	Maintenance	Tap 2	9:15 AM	
0303-ER-012	565 Girls	Tap 1	9:20 AM	
0303-ER-013	566 Girls	Tap 2	9:20 AM	
0303-ER-014	563 Boys	Tap 1	9:22 AM	
0303-ER-015	564 Boys	Tap 2	9:22 AM	
0303-ER-016	Men's 100D	Tap	9:25 AM	
0303-ER-017	100E Teacher's Lounge	Tap	9:26 AM	
0303-ER-018	100C Womens	Tap	9:27 AM	
0303-ER-019	Dishwasher Room	Sprayer	9:29 AM	
0303-ER-020	Hall by Cafeteria	Chiller 1	9:30 AM	
0303-ER-021	Hall by Cafeteria	Chiller 2	9:31 AM	
0303-ER-022	Hall by Cafeteria	Bottle filler	9:32 AM	
0303-ER-023	501M Fork Room	Tap	9:34 AM	
0303-ER-024	507B Nurse	Tap	9:37 AM	
0303-ER-025	507C Hearing	Tap	9:37 AM	
0303-ER-026	511 Girls	Tap 1	9:42 AM	
0303-ER-027	512 Girls	Tap 2	9:42 AM	
0303-ER-028	513 Girls	Tap 3	9:43 AM	
0303-ER-029	514 Girls	Tap 4	9:43 AM	
0303-ER-030	515 Girls	Tap 5	9:43 AM	
0303-ER-031	509 Boys	Tap 1	9:47 AM	
0303-ER-032	510 Boys	Tap 2	9:47 AM	
0303-ER-033	511 Boys	Tap 3	9:48 AM	
0303-ER-034	512 Boys	Tap 4	9:49 AM	
0303-ER-035	513 Boys	Tap 5	9:49 AM	
0303-ER-036	Hall by 511	Chiller 1	9:53 AM	
0303-ER-037	Hall by 511	Chiller 2	9:54 AM	



SCHNEIDER LABORATORIES GLOBAL, INC.

2512 West Cary Street, Richmond, Virginia 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475
www.slabin.com e-mail: info@slabin.com

R 37

407820
V:407407820

fghraizi 3/10/2021 9:56:34 AM
UPS 1Z2E28999068320843

Submitting Co. LaBella Associates, D.P.C. Lab WO# Phone
Acct # 1126 Fax/Email cstamp@labellapc.com
Rochester, New York 14614
Project Name: 2020 Lead in Drinking Water Testing
Project Location: East Rochester Union Free School District
Project Number: 2202959

Turn Around Time Matrix / Sample Type (Select ONE) Tests / Analytes (Select ALL that Apply)
2 hours* Same day* 1 business day* 2 business day* 3 business days* 5 business days*
Air Aqueous Bulk Hi-Vol Filter (PM10) Hi-Vol Filter (TSP) Oil Paint Sludge Soil
Solid Waste Wastewater Water, Drinking Compliance Wipe Wipe, Composite
Asbestos Air / Fiber Counts Asbestos Bulk / AsbID Metals-Total Conc.
PCM (NIOSH 7400) TEM (AHERA) TEM (EPA Level II) PLM (EPA 600/R-93/116) PLM (EPA Point Count) PLM (Qualitative only) NYELAP 198.1/4.6
Miscellaneous Tests Total Dust (NIOSH 0500) Resp. Dust (NIOSH 0600) Silica - FTIR (NIOSH 7602) Silica - XRD (NIOSH 7500) Mold Direct Exam
FOR ASBESTOS AIR: TYPE OF RESPIRATOR USED:

Table with columns: Sample #, Date Sampled, Time Sampled, Sample Identification, Wiped Area, pH / Temp, Time, Flow Rate, Total Air. Contains handwritten text: 'See attached spreadsheet'.

Sampled by Cory Stamp Relinquished to lab by Cory Stamp
Sample Disposal: Return to Sender, Disposal by lab
Shipping Methods: FX, HD, UPS, DB, USM
* Sample return requested Ambient temp Ice Cl R S X Receive a physical copy of report.

* Temperature taken with IR Gun A. **Required. Chain-of-Custody documentation continued internally within lab. Terms and conditions page 2.